

July 20, 1989

Mr. Matthew K. Miyasato
P.O. Box 1176
Kealakekua, HI 96750

Dear Mr. Miyasato:

Obama Dwelling Permit (OD 89-211)
Tax Map Key: 7-9-04:14

The subject application has been reviewed by the concerned agencies and note:

1. The subject tax map key parcel is served by an acceptable street;
2. The subject application can meet with the State Department of Health wastewater treatment and disposal systems requirements;
3. The copy of document(s) received relating to subject tax map key parcel to establish title and exhibits contained therein do not include any deed restriction or covenant to prohibit construction of requested Obama dwelling; and,
4. The submitted site plan denotes two off-street parking stalls on the property.

In view of the above, by this letter, you are hereby granted permission to construct the Obama Dwelling subject to the following condition(s):

- (a) The building permit for the Obama Dwelling shall be secured on or before July 20, 1991. If the applicant and/or owner fails to secure a building permit within two (2) years of the date of this letter, permission to construct the subject Obama dwelling shall be deemed void. A time extension may be granted for good cause, provided, the permittee and/or owner applies in writing at least forty-five (45) calendar days before the expiration of the two (2) year period.

JUL 24 1989

Mr. Matthew K. Miyasato
Page 2
July 20, 1989


- (b) Off-street parking space for two vehicles is designated on the submitted site plan to fulfill the off-street parking requirement. The off-street parking spaces may not be employed for storage or other use unless and until approved alternative on-site parking arrangements are established.
- (c) All construction drawings together with approved site plan drawn to scale submitted with the ohana dwelling building permit application shall denote location and identify required two (2) off-street parking spaces.
- (d) The ohana dwelling shall conform to all requirements of codes and statutes pertaining to access and building construction.
- (e) The applicant shall conform to State Department of Health standards and regulations and following comment(s) dated June 30, 1989:

"An individual wastewater system may service a maximum of 300 gallons per day of sewage, which is generated from a single or multiple dwelling unit complex, containing a total of only four (4) bedrooms.

The minimum setback requirements for cesspools, as per Administrative Rules 11-62, must be met."
- (f) This Ohana Dwelling permit is subject to all other applicable rules, regulations and requirements, including but not limited to those of the Planning Department, Department of Public Works, and State Department of Health.

Please bring or attach a copy of this Permit to expedite processing the building plans and building permit application to construct the ohana dwelling. Should you have any questions regarding the above, please feel free to contact either Mana Ohuma or William Yamanoha of my staff at 961-8288.

Sincerely,



DOANE KANUHA
Planning Director

WRY:etn

cc: Department of Health,
Chief Sanitarian
Department of Public Works
Real Property Tax Division

GRANT 1598 TO

WILLIAM JOHNSON

T.M.K.: 7-9-05-14


TRUE NORTH
SCALE: 1 IN TO 20 FT
78'
SCALE IN FEET

GRANT

PROPOSED DWELLING

E

LOT 21
T 0
R 04:01
T.M.K. 7-9-05-14



MAP SHOWING

LOT-D1

AND

SITE FOR PROPOSED

DWELLING

BEING A LOT OF THE
PARTITION SURVEY OF

GRANT 974 TO EHU BY

H.N. AHLINA,

DATED: SEPTEMBER 20TH, 1927

LAND SITUATED AT KUAMOO 1ST TO 3RD
NORTH-KONA, HAWAII - HAWAII

NOTES:

1.- BOUNDARY INFORMATION
OBTAINED FROM ATTACHED
DESCRIPTION OF CIVIL NO.
8228 - DECREE QUIETING
TITLE DATED: JULY 26TH, 1984

