

February 8, 1991

Mr. and Mrs. Travis Tarumoto
P.O. Box 2329
Kealahou, HI 96750

Dear Mr. and Mrs. Tarumoto:

Ohana Dwelling Permit (OD 89-642)
Tax Map Key: 7-7-03:78, Lot 8

The subject application has been reviewed by the concerned agencies and note:

1. The subject tax map key parcel is served by an acceptable street;
2. The subject application can meet with the State Department of Health wastewater treatment and disposal systems requirements;
3. The copy of document(s) received relating to subject tax map key parcel to establish title and exhibits contained therein do not include any deed restriction or covenant to prohibit construction of requested ohana dwelling; and,
4. The submitted revised site plan denotes two off-street parking stalls on the property.

In view of the above, by this letter, you are hereby granted permission to construct the Ohana Dwelling (DUPLEX CONVERSION), subject to the following condition(s):

- (a) 1. Please complete and return Cancellation of Agreement form together with \$10.00 check payable to the Bureau of Conveyances prior to submission of the building permit application for the duplex conversion.
2. The building permit for the Ohana Dwelling shall be secured on or before January 11, 1992. If the applicant and/or owner fails to secure a building permit within two (2) years of the date of this letter, permission to construct the subject ohana dwelling shall be deemed void. A time extension may be granted for good cause, provided, the permittee and/or owner applies in writing at least forty-five (45) calendar days before the expiration of the two (2) year period.

FEB 11 1991

Mr. and Mrs. Travis Tarumoto

Page 2

February 8, 1991

- (b) Off-street parking space for two vehicles is designated on the submitted revised site plan to fulfill the off-street parking requirement. The off-street parking spaces may not be employed for storage or other use unless and until approved alternative on-site parking arrangements are established.
- (c) All construction drawings together with approved revised site plan drawn to scale submitted with the Ohana Dwelling building permit application shall denote location and identify required two (2) off-street parking spaces.
- (d) The Ohana Dwelling shall conform to all requirements of codes and statutes pertaining to access and building construction.
- (e) The applicant shall conform to State Department of Health standards and regulations and following comment(s) dated February 4, 1991:

*Per Administrative Rule, Title 11, Chapter 62, 'Wastewater', a single individual wastewater system (IWS) may receive no more than 800 gallons per day of sewage which is generated from a single or multiple unit complex containing a total of no more than four (4) bedrooms. Developments that exceed four (4) bedrooms must install another individual wastewater system.

The minimum setback requirements for an IWS as per Administrative Rules 11-62 must be met. The minimum setback distances noted on the applicants' site plan for the IWS is in error. The minimum distances from the IWS to the wall line of the dwelling is no less than 5 feet; from the IWS to the property line no less than 10 feet.

The Department of Health would like to inform the applicant that wastewater rules are in the process of change and that comments on the project may change accordingly.*

- (f) This Ohana Dwelling permit is subject to all other applicable rules, regulations and requirements, including but not limited to those of the Planning Department, Department of Public Works, and State Department of Health.

Please bring or attach a copy of this Permit to expedite processing the building plans and building permit application to construct the Ohana Dwelling. Should you have any questions

Mr. and Mrs. Travis Tarumoto
Page 3
February 8, 1991

regarding the above, please feel free to contact either Masa Onuma
or William Yamano of my staff at 941-6288.

Sincerely,



NORMAN K. HAYASHI
Planning Director

NRV/BO:etn

Enc.

cc: Department of Health,
Chief Sanitarian
Department of Public Works
Real Property Tax Division

16.
ON

193.11' 352°00' →

PROVIDE POSITIVE DRAINAGE
AROUND HOUSE

CESS POOL PER
D.O.M. REQUIREMENT
MIN. 10' FROM HOUSE
5'-0" FROM FL

260°19' → 84.34'

15' SETBACK 25'

259°27' → 40.76'

25' S.B.

152.73' ← 171°17'

PROPOSED TWO
CAR ENCLOSED
GARAGE BELOW

PROPOSED TWO STORY DUPLEX

2 BEDROOMS	2 BA	UPSTAIRS
2 BEDROOMS	1 BA	DOWNSTAIRS
4 BEDROOMS		3 BA TOTAL

25' S.B.

100.02' ← 88°34'
KALAMAIKA ST.

MAUKA

HALA  KAIU
MAKAI

SITE PLAN

1"=20'