

December 15, 1993

Mr. Michael B. Carter  
200 Kanoelehua Ave., Suite 103-305  
Hilo, HI 96720

Dear Mr. Carter:

Ohana Dwelling Permit (OD 93-357)  
Tax Map Key: 1-5-84:63, Lot 22

3355

The subject application has been reviewed by the concerned agencies and note:

1. The subject tax map key parcel is served by an acceptable street;
2. The subject application can meet with the State Department of Health wastewater treatment and disposal systems requirements;
3. The copy of document(s) received relating to subject tax map key parcel to establish title and exhibits contained therein do not include any deed restriction or covenant to prohibit construction of requested ohana dwelling; and,
4. The site plan dated November 9, 1993 denotes two off-street parking stalls on the property.

In view of the above, by this letter, you are hereby granted permission to construct the Ohana Dwelling (Additional Single Family Dwelling), subject to the following condition(s):

- (a) The building permit for the Ohana Dwelling shall be applied for and secured from the Department of Public Works, Building Division on or before December 15, 1994. It should be noted that the permit is effective for only one (1) year and should applicant fail to secure a building permit within this period, a new application must be applied for.

Please bring or attach a copy of this Permit to expedite processing the building plans and building permit application to construct the ohana dwelling.

11023

DEC 17 1993

Mr. Michael B. Carter  
Page 2  
December 15, 1993


- (b) Off-street parking space for two vehicles is designated on the submitted site plan to fulfill the off-street parking requirement. The off-street parking spaces may not be employed for storage or other use unless and until approved alternative on-site parking arrangements are established.
- (c) All construction drawings together with approved site plan drawn to scale submitted with the ohana dwelling building permit application shall denote location and identify required two (2) off-street parking spaces.
- (d) The ohana dwelling shall conform to all requirements of codes and statutes pertaining to access and building construction.
- (e) The applicant shall conform to State Department of Health standards and regulations and following comment(s) dated December 6, 1993:

"The existing cesspool may service a total of 1,000 gallons per day of wastewater. A total of five bedrooms are allowed in the two dwelling units. A second Individual Wastewater System is not allowed because of lack of land area."

- (f) This Ohana Dwelling permit is subject to all other applicable rules, regulations and requirements, including but not limited to those of the Planning Department, Department of Public Works, and State Department of Health.

Should you have any questions regarding the above, please feel free to contact Gilbert Bailado of my staff at 961-8288.

Sincerely,

*for*   
VIRGINIA GOLDSTEIN  
Planning Director

GB:mjs  
1931D (3)

xc: Department of Health,  
Chief Sanitarian  
Department of Public Works  
Real Property Tax Division - Hilo

DEPARTMENT OF PUBLIC WORKS

ENGINEERING DIVISION

DRIVEWAY: IN ACCORDANCE WITH CHAPTER 22 OF THE HAWAII COUNTY CODE, A PERMIT SHALL BE OBTAINED FOR DRIVEWAY CONSTRUCTION WORK WITHIN THE COUNTY ROAD RIGHT-OF-WAY.

GRADING: ALL EARTHWORK AND GRADING SHALL CONFORM TO CHAPTER 10 OF THE HAWAII COUNTY CODE. A PERMIT MAY BE REQUIRED FOR LOT GRUBBING AND/OR GRADING.

DRAINAGE: NO ADDITIONAL RAINFALL RUNOFF GENERATED BY THIS PROJECT SHALL BE DISPOSED OF ONTO COUNTY ROADWAYS OR ADJACENT PROPERTIES. ALL DRAINAGE IMPROVEMENTS SHALL CONFORM TO CHAPTER 27 OF THE HAWAII COUNTY CODE.

Min. 20' 0"  
Rear Yard  
Setback Required

DEPARTMENT OF PUBLIC WORKS

ENGINEERING DIVISION

REVIEWED BY: *[Signature]*

DATE: 6/02/94

Min. 10' 0"  
Side Yard  
Setback Required

Min. 15' 0"  
Side Yard  
Setback Required

172.00

172.00

DRIVEWAY

PARKING

PROPOSED STUDIO

EXISTING CROSSPOOL

EXISTING RESIDENCE

Min. 20' 0"  
Front Yard  
Setback Required

70.00

LOT PLAN 11' 20' 0"

APPROVED

*[Signature]*

Director, County Planning Department

Date: 6/2/94

1-5-84:63

20 GA. GALV. IRON ROOF