

CERTIFIED MAIL

September 20, 1990

Mr. and Mrs. Samuel Alameda  
561 Alawaena Road  
Hilo, Hawaii 96720

Dear Mr. and Mrs. Alameda:

Variance Application (V90-12)  
Variance from Minimum Water Requirements  
Tax Map Key 2-4-07:137 & 138

After reviewing your application and the information submitted in behalf of it, the Planning Director by this letter hereby certifies the approval of your variance request to allow a consolidation and resubdivision of two 6-acre lots into four 3-acre lots without meeting the standard water requirements of the Subdivision Code. The subject property is 12 acres in area, identified by tax map key 2-4-07:137 and 138 and is located at the end of a 1900 ft. long private road off (southeast) Alawaena Road, and 5600 ft. (west) from its junction with Malaai Street in the upper Waiakea Homesteads, South Hilo, Hawaii.

The approval is based on the following:

SPECIAL AND UNUSUAL CIRCUMSTANCES

There are special and unusual circumstances applying to the subject property which deprive the applicants of substantial property rights that would otherwise be available, or which interfere with the best use or manner of development of the property.

The County water system, does not service the property, due to the physical limitations of the water network and capacity. The land is, in all other respects, suitable for the 4-lot subdivision. If the public system were able to be utilized there would be no need for a variance request in this development.

SEP 21 1990

September 20, 1990

Based on the foregoing, it has been determined that there are special and unusual circumstances applying to the subject property which exist to a degree which deprive the owner of substantial property rights that would otherwise be available, or which unreasonably interfere with the best use or manner of development of the property.

#### ALTERNATIVES

There are no reasonable alternatives available to resolve the existing insufficient source and system. Only extensive improvements to the County water service system would alleviate the situation, and no timetable nor funding is presently available from the Department of Water Supply.

Developing a private roof catchment system to provide the development with water is the only other reasonable means available to the owner at this time. An analysis of the annual median rainfall for the area indicates that there is sufficient rainfall, over 180 inches annually, to support an adequate water roof catchment and storage system.

#### INTENT AND PURPOSE

The intent and purpose of the water requirement of the Subdivision Code is to ensure that adequate potable water is made available for human consumption and, in higher densities, for fire protection. Lacking sufficient public or private piped water systems to connect to, the presence of an adequate rainfall catchment and storage capacity is deemed an acceptable substitution for limited size developments.

Therefore, in consideration of the zoning designation, property rights of the owner, family disposition of the lots and the practical possibility in the future for improvements to the existing County water system, the variance request is found to be consistent with the general purpose of the zoning Code and the County General Plan; will not be materially detrimental to the public's welfare; and will not cause substantial adverse impact to the area's character and adjoining properties, provided certain conditions are met.

Therefore, the Planning Director has concluded that this variance request be approved subject to the following conditions:

1. The applicants, their assigns or successors, shall be responsible for complying with all stated conditions of approval.

2. The applicants, their assigns or successors, shall file a written agreement with the Planning Department prior to receipt of final subdivision approval containing the following stipulations and covenants:
  - a. That the subdivider agrees and accepts the fact that a County dedicable public water system is not now or in the foreseeable future able to service the subdivision, and that no portion of the subject property may be further subdivided without first having a water system meeting with the standards of the Department of Water Supply.
  - b. That the subdivider agrees and accepts the fact that the County will not at any time bear the responsibility of supplying public water to the subdivision.
  - c. That any future dwellings constructed on the property shall have a minimum of 800 square feet roof catchment surface with a minimum 7500 gallon water storage facility plus adequate start up supply.
  - d. That no ohana dwellings will be permitted on any lots that are not served by the County water system.
3. In the event that there are any amendments or changes to the subdivision after the agreement is signed, the subdivider shall be responsible for informing the Department of the amendments or changes so that the agreement can reflect the amendments or changes; further, the written agreement shall be considered as a condition and covenant running with the land and shall be binding upon the subdivider or owner, his heirs, executors, administrators or assigns and its successors and assigns and shall be incorporated as an exhibit and made part of each agreement of sale, deed, lease or other similar documents affecting the title or ownership of each subdivided lot.
4. In the event that any of the lots are provided by a water service (individual meter) from the Department of water supply or an approved private water system, the above covenants for the specific property will no longer be in effect.

Mr. and Mrs. Samuel Alameda  
Page 4  
September 20, 1990

5. Comply with any subdivision conditions concerning the future development of lots 5 and 6 which are still applicable and outstanding (Planning Department's letter of February 14, 1980 attached).
6. All other applicable State and County rules and regulations shall be complied with. Should any of the foregoing conditions not be met, the Director may proceed to declare the variance null and void.

If you have any questions on this matter, please feel free to contact us.

Sincerely,



DUANE KANUHA  
Planning Director

DT:lm  
Att.

cc: Subd. 89-185 w/att.