

Harry Kim
Mayor



Michael Yee
Director

Daryn Arai
Deputy Director

West Hawai'i Office
74-5044 Ane Keohokalole Hwy
Kailua-Kona, Hawai'i 96740
Phone (808) 323-4770
Fax (808) 327-3563

County of Hawai'i
PLANNING DEPARTMENT

East Hawai'i Office
101 Pauahi Street, Suite 3
Hilo, Hawai'i 96720
Phone (808) 961-8288
Fax (808) 961-8742

August 2, 2018

Niels Christensen, LPLS
The Independent Hawaii Surveyors, LLC
P.O. Box 577
Hilo, HI 96721

Dear Mr. Christensen:

SUBJECT: VARIANCE DECISION - VARIANCE - VAR-18-000479
Applicant: NIELS CHRISTENSEN, LPLS, THE INDEPENDENT HAWAII SURVEYORS, LLC
Owners: BHD GROUP, LLC
Request: Variance from Chapter 23, Subdivisions, Article 6, Division 2, Improvements Required, Section 23-84, Water Supply
Tax Map Key: 2-8-014:013 (SUB-17-001772)

Upon review of your variance application, the Planning Director certifies the **approval** of Variance VAR-18-000479, subject to variance conditions. The variance grants relief for SUB-17-001772 from constructing minimum County dedicable water supply system improvements for the one (1) of the two (2) lots as required by Hawai'i County Code (HCC), Chapter 23 (Subdivisions).

The variance is from the proposed subdivision's minimum requirements pursuant to HCC, Chapter 23 (Subdivisions), Article 6, Division 2, Improvements Required, Section 23-84, Water Supply, (1)(2).

BACKGROUND

1. **Location.** The referenced property, Lot 1, Honomū Ocean View Estates, being also a portion of Grant 899, containing approximately 39,810 sq. ft., is situated at Honomū, South Hilo, Hawai'i.

2. **County Zoning.** Residential Single-Family, 10,000 sq. ft. (RS-10) and Village Commercial, 10,000 sq. ft. (CV-10).
3. **State Land Use.** Urban (U).
4. **General Plan.** Land Use Pattern Allocation Guide (LUPAG) map designates the property as Low Density Urban (ldu).
5. **Subdivision Code Requirements.** The subdivision code requires that subdivisions be served by a water system meeting the minimum requirements of the County Department of Water Supply (DWS) and be provided with water mains and fire hydrants installed to and within the subdivision in accordance with the rules and regulations of the DWS.
6. **Subdivision Request/PPM.** Subdivision application SUB-17-001772 was submitted to subdivide the subject TMK property into 2 lots. Further action on the subdivision application has been deferred pursuant to this variance application submitted on April 24, 2018 in response to Department of Water Supply letter dated February 1, 2018 informing that the department was unable to supply the additional unit of water to the additional lot in the proposed subdivision.
7. **Variance Application.** The variance request from water supply improvements for one (1) of the two (2) lots was acknowledged by Planning Department letter dated May 14, 2018. This variance application includes background history and circumstances and information regarding the pending subdivision application. Although the parcel is served by one water meter, additional water cannot be made available for the one (1) additional proposed lot without extensive water system facilities improvements.
8. **Agency Comments and Requirements.**
 - a. State of Hawai'i-Department of Health (DOH): See attached memorandum dated December 26, 2017. **(Exhibit A).**
 - b. County of Hawai'i Fire Department (HFD): Although the HFD did not comment on this application, see attached memoranda that is their standard response to applications of this type. **(Exhibit B).**
 - c. Department of Water Supply (DWS): See attached memoranda dated February 1, 2018 in response to the subdivision application. **(Exhibit C).**
 - d. No other agency comments were solicited and none were received.

9. **Notice to Surrounding Owners/Posted Sign.** The applicant submitted evidence, dated May 14, 2018, regarding the posting of a public notification sign on the subject property pursuant to Section 23-17(c) of the Hawai'i County Code (HCC). Pictures of the posted sign were also submitted. The evidence also indicates that a notice of the application was sent to the surrounding property owners as required by Section 23-17(a).
10. **Comments from Surrounding Property Owners or Public.** There were no written comments on this application received from the surrounding property owners or the public.

ANALYSIS OF GROUNDS FOR VARIANCE

No variance will be granted unless it is found that:

- (a) *There are special or unusual circumstances applying to the subject real property which exist either to a degree which deprives the owner or applicant of substantial property rights that would otherwise be available or to a degree which obviously interferes with the best use or manner of development of that property.*

The Variance application meets criterion (a) for the following reasons(s):

The subdivision request is for two (2) lots in keeping with the existing RS-10 & CV-10 zonings. Although a dedicable water system is a requirement of the code, it would be unreasonable for the subdividers alone to shoulder the costs associated with upgrading the DWS system to further service the subject property and the one (1) additional proposed subdivided lot. It would be unreasonable to expect the owners to construct the required service facilities upgrades and extensions to serve one (1) of the two (2) lots. Therefore, in lieu of constructing water system improvements to either extend/upgrade the DWS facilities or provide a private water system to DWS standards for the pending 2-lot subdivision, a more reasonable alternative can be allowed through Rule 22, Water Variance.

The above special and unusual circumstances would deprive the applicant from developing this property and interferes with the best use of this property.

Therefore, for this 2-lot subdivision, the best use and manner of the development allows for individual rain water catchment system in keeping with the urban residential character of the area.

(b) *There are no other reasonable alternatives that would resolve the difficulty.*

The Variance application meets criterion (b) for the following reasons(s):

The DWS has indicated that the property is not able to be served with additional water beyond the one existing meter without the upgrade to the present water system facilities. Constructing water system improvements to upgrade the DWS facilities or provide a private water system to DWS standards for one (1) lot of the pending 2-lot subdivision would be placing excessive demands upon the applicant because of the extensive improvements and additions required to upgrade the existing DWS water system facilities. And, at an elevation of approximately 300 feet above sea level, the drilling of wells and construction of other water system improvements to DWS standards would also be unreasonable for one additional lot of a 2-lot subdivision.

(c) *The variance will be consistent with the general purpose of the district, the intent and purpose of this chapter, and the County general plan and will not be materially detrimental to the public welfare or cause substantial, adverse impact to an area's character or to adjoining properties.*

The Variance application meets criterion (c) for the following reasons(s):

Given that there is adequate rainfall (approximately 120 inches to 160 inches annually) to support individual water catchment for one (1) of the two (2) lots, the granting of this variance would be consistent with the general purpose of the district. Water catchment is consistent with the intent of the policies of the general plan in that it will further housing opportunities in this urban residential area. Water catchment will not be materially detrimental to the public welfare as it serves only private parties.

Subject to conditions, granting of the variance will not cause substantial, adverse impact to the area's character or to adjoining properties. The collection of rainwater could help to reduce runoff and may be a benefit to the surrounding area.

Given that the subject area receives sufficient annual rainfall, a water variance would be consistent with the general purpose of the zoning district, the intents and purposes of the Zoning Code, Subdivision Code and the Hawai'i County General Plan.

DETERMINATION-VARIANCE CONDITIONS

The variance to permit the proposed 2-lot subdivision of the subject TMK property without providing dedicable water system improvements meeting DWS standards, is hereby **approved** subject to the following variance conditions:

1. The applicant, owners, their assigns, or successors shall be responsible for complying with all stated conditions of approval.
2. Should the Council adopt a Unified Impact Fees Ordinance setting forth criteria for the imposition of exactions or the assessment of impact fees, conditions included herein shall be credited towards the requirements of the Unified Impact Fees Ordinance.
3. The owners, their assigns, or successors shall file a written agreement document with the Planning Department within one (1) year from the issuance of tentative subdivision approval. This written agreement shall contain deed language, being covenants, conditions, and restrictions affecting the two (2) lots created by the proposed subdivision which are not serviced by a County dedicable public water system.

The agreement shall be duly recorded at the State of Hawai'i Bureau of Conveyances by and at the cost and expense of the owners. A copy of the recorded document shall be supplied to the Planning Department for our files.

In the event that there are any amendments or changes to the subdivision after the agreement is signed, the applicant shall be responsible for informing the County Planning Department of such amendments or changes so that the agreement can be amended concomitantly. Further, the recorded agreement shall be binding upon the owner(s), their successors or assigns and shall be incorporated as an exhibit and made part of each agreement of sale, deed, lease, or similar documents affecting the title of the existing property or approved subdivided lots.

4. The subdivider and all grantees, successors, and assigns acknowledge that the parcels were created by a variance, from the normal subdivision requirements of Hawai'i County, and that there are no longer any special or unusual circumstances applying to the property, and hence, no grounds exist or will exist for another variance, from the Subdivision Code to permit further subdivision of the properties, unless County dedicable public water system requirements and other requirements of HCC Chapter 23, Subdivisions, are met.

5. The owners, grantees, successors, and assigns agree and accept the fact that a County dedicable public water system, will not be extended, to serve the lots within proposed subdivision SUB-17-001772.
6. The owners, grantees, successors, and assigns agree and accept the fact that the County will not bear the responsibility of supplying additional public water to the subdivided lots. No further subdivision of the lots will be permitted unless County dedicable public water system requirements and other requirements of HCC Chapter 23, Subdivisions, are met.
7. No condominium property regime will be allowed, nor will an Ohana Dwelling Unit be permitted or allowed.
8. Any dwelling constructed on any created lot not served by the DWS, shall be provided with and maintain a private rainwater catchment system, which includes a minimum 6,000-gallon water storage capacity for domestic consumption or potable uses. This private water storage system shall adhere to the University of Hawai'i's College of Tropical Agriculture and Human Resources' "Guidelines on Rainwater Catchment Systems for Hawai'i", as well as the DOH requirements related to water testing and water purifying devices.
9. A fire hydrant was installed when the original subdivision was created so there are no additional water storage for emergency and firefighting requirements.
10. In the event that the County notifies the owner(s) of the lot(s) created that the County water system has been upgraded or an improvement district initiated to enable service to the lots, the owner(s) of the lots shall participate in such improvement district or shall pay their pro-rata share of the upgrade and installation of laterals, as determined by the DWS.
11. The pending subdivision application's (SUB-17-001772) final plat map shall meet all the requirements of the Hawai'i County Zoning Code and the Subdivision Code that are not covered by this variance. In keeping with the intent of variance 502 (92-23) and denied variance VAR-12-000102, a "no vehicular access" planting screen easement shall be shown along Kokoke Kai Place for the entire Lot 1-B frontage. This will be included as a condition of Tentative Approval for SUB-17-001772.
12. The subdivider, owner(s), their assigns or successors shall pay any outstanding real property taxes and comply with all other applicable State statutes and County ordinances pertaining to building improvements, land use and the public's health, safety and welfare.

Niels Christensen, LPLS
The Independent Hawaii Surveyors, LLC
Page 7
August 2, 2018

Should any of the foregoing conditions not be complied with, the Planning Director may proceed to declare this Variance Permit null and void.

Sincerely,



MICHAEL YEE
Planning Director

JRH:nci

\\COH33\planning\public\Admin Permits Division\Variance\2018\VAR-18-000479 BHD Group LLC Water\APVL.docx

Encls: Agency Comments, Exhibits A-C

xc: DWS-Engineering Branch
HFD
SUB-17-001772
VAR-502
A. Surprenant, HCDP PPM (via e-mail)

xc w/encls: BHD Group, LLC
c/o Annette Barr
P.O. Box 971
Pepe'ekeo, HI 96783
G. Bailado, GIS Section (via email)



STATE OF HAWAII
DEPARTMENT OF HEALTH
P.O. BOX 916
HILO, HAWAII 96721-0916

2017-DEC 27 AM 10 45
PLANNING DEPARTMENT
COUNTY OF HAWAII

MEMORANDUM

DATE: December 26, 2017

TO: Mr. Michael Yee
Planning Director, County of Hawaii

FROM: Eric Honda ^{EH}
District Environmental Health Program Chief

SUBJECT: PRELIMINARY PLAT MAP AND DEFER ACTION
Proposed Subdivision of a Portion of Lot 1, Honomu Ocean View Estates,
Being also a Portion of Grant 899 and Grant (P.W.) 39
Into Lots 1-A and 1-B
Honomu, South Hilo, Island of Hawaii, Hawaii
TMK: 2-8-014:013 (SUB-17-001772)

The applicant would need to meet the requirements of our Department of Health Air Pollution Rules, Chapter 60.1, Title 11, State of Hawaii for fugitive dust control. If there is need to discuss these requirements, please contact our Clean Air Branch staff at Ph. 933-0401.

The Department of Health (DOH), Clean Water Branch (CWB), acknowledges receipt of the subject document on December 20, 2017. The CWB has reviewed the limited information contained in the subject document and offers the following comments:

Permit Issuance

- * Any project and its potential impacts to State waters must meet the State's:
 - 1) Antidegradation policy, which requires that the existing uses and the level of water quality necessary to protect the existing uses of the receiving State water be maintained and protected;
 - 2) Designated uses, as determined by the classification of the receiving State waters; and
 - 3) Water quality criteria [Hawaii Administrative Rules (HAR), Chapter 11-54],
- * A Section 401 Water quality Certification (WQC) is required if your project/activity:

EXHIBIT
A

115709

- Requires a federal permit, license, certificate, approval, registration, or Statutory exemption; and
- May result in a discharge into State waters. The term “discharge” is defined in Clean Water Act, Subsections 502(16), 502(12), and 502(6). Examples of “discharge” include, but are not limited to, allowing the following pollutants to enter State waters from the surface or in-water: solid waste, rock/sand/dirt, heat, sewage, construction debris, any underwater work, chemicals, fugitive dust/spray/paint, agricultural wastes, biological materials, industrial wastes, concrete/sealant/epoxy, and washing/cleaning effluent.

Determine if your project/activity requires a federal permit, license, certificate, approval, registration, or statutory exemption by contacting the appropriate federal agencies (e.g. Department of the Army (DA), U.S. Army Corps of Engineers (COE), Pacific Ocean Division Honolulu District Office (POH) Tel: 808-835-4303; U.S. Environmental Protection Agency Tel: 415-947-8021; Federal Energy Regulatory Commission Tel: 866-208-3372; U.S. Coast Guard Office of Bridge Programs Tel: 202-372-1511).

To request a Section 401 WQC, you must complete and submit the Section 401 WQC application. This application is available on the e-Permitting Portal website located at: <https://eha-cloud.doh.hawaii.gov/epermit/>.

Please see HAR, chapter 11-54 for the State’ Water Quality Standards and for more information on the Section 401 WQC. HAR, Chapter 11-54 is available on the CWB website at: <http://health.hawaii.gov/cwb/>.

- National Pollutant Discharge Elimination System (NPDES) permit coverage is required for:
 - Storm water associated with construction activities for land disturbances of one (1) acre or more. Land disturbance includes, but is not limited to, clearing, grading, grubbing, excavation, demolition, uprooting of vegetation, equipment staging, and storage areas.
 - Storm water associated with industrial activities for facilities with Standard Industrial Classification Codes regulated in 40 CFR 122.26(b)(14)(i) through (ix) and (xi).
 - Storm water and certain non-storm water from a small Municipal Separate Storm Sewer System.
 - Discharges of water pollutants into State surface waters. Examples of these discharges include, but are not limited to, cooling water, hydrotesting waters, dewatering effluent, and process wastewater.
 - Discharges from the application of pesticides (including pesticides, herbicides, fungicides, rodenticides, and various other substances to control pest) to State waters.

An application for an NPDES individual permit must be submitted at least 180 calendar days before the commencement of the discharge or start of construction activities. To request and NPDES individual permit, you must complete and submit the NPDES individual permit application. This application is available on the e-Permitting Portal website located at:
<https://eha-cloud.doh.hawaii.gov/epermit/>.

A Notice of Intent (NOI) for coverage under a specific NPDES general permit must be submitted at least 30 calendar days before the commencement of the discharge or start of construction activities. To request NPDES general permit coverage, you must complete and submit the NOI. The NOI is available on the e-Permitting Portal website located at:
<https://eha-cloud.doh.hawaii.gov/epermit/>.

Please see HAR, Chapter 11-55 for more information on the NPDES individual permit and NPDES general permits. The specific NPDES general permits located in HAR, Chapter 11-55, Appendices B through M. HAR, Chapter 11-55 and HAR, Chapter 11-55, Appendices B through M are available on the CWB website at: <http://health.hawaii.gov/cwb/>.

- According to State law, all discharges related to the project construction or operation activities, whether or not NPDES permit coverage and/or Section 401 WQC are required, must comply with the State's Water Quality Standards.

Monitoring

- Effluent discharge and/or receiving water monitoring may be required as conditions of Section 401 Water Quality Certifications and NPDES General and Individual permits.

Enforcement

- Noncompliance with water quality requirements contained in HAR, Chapter 11-54 and/or permitting requirements specified in HAR, Chapter 11-55 may be subject to penalties of \$25,000 per day per violation.
- Violations of Hawaii Revised Statutes 342D and 342E may elicit administrative, civil and criminal penalties for such violations.

Polluted Runoff Control

- Manage projects identified in watershed-based plans that reduce polluted runoff and educate the public about nonpoint source pollution. Projects are selected through an annual request for proposals. Funding is provided by the EPA through the Clean Water Act. For more information on projects and funding opportunities, please visit: www.hawaii.gov/doh/pollutedrunoffcontrol.

Michael Yee
December 26, 2017
Page 4 of 4

If you have any questions, please contact Ms. Joanne Seto, Supervisor of the Engineering Section, CWB, at (808) 586-4309.

Construction activities must comply with the provisions of Hawaii Administrative Rules, Chapter 11-46, "Community Noise Control."

- a. The contractor must obtain a noise permit if the noise levels from the construction activities are expected to exceed the allowable levels of the rules.
- b. Construction equipment and on-site vehicles requiring an exhaust of gas or air must be equipped with mufflers.
- c. The contractor must comply with the requirements pertaining to construction activities as specified in the rules and the conditions issued with the permit.

Should there be any questions on this matter, please contact the Department of Health at 933-0917.

Lands formerly used for sugarcane production are now being developed into communities where residential homes, schools and commercial businesses are being constructed. Chemicals associated with the sugarcane industry persist in soil today and may be a threat to public health and the environment. Elevated arsenic levels were discovered in soil at former sugarcane production areas on the islands. The HEER Office has identified former sugarcane production areas for assessment throughout the state and plans to work with property owners to conduct environmental assessments to identify and address elevated soil arsenic levels prior to finalizing development plans for the properties.

Wastewater Branch does not concur with the proposed project. Information on existing structure and wastewater system locations was not shown on the drawings and we are unable to provide comments. Please have your engineer identify the locations of all existing structures and wastewater systems and their relationship to all proposed property lines to make sure they meet the minimum standard setback distances required per Hawaii Administrative Rules, Chapter 11-62.

We recommend that you review all of the Standard Comments on our website: <http://hawaii.gov/health/environmental/env-planning/landuse/landuse.html>. Any comments specifically applicable to this project should be adhered to.

The same website also features a Healthy Community Design Smart Growth Checklist (Checklist) created by Built Environment Working Group (BEWG) of the Hawaii State Department of Health. The BEWG recommends that state and county planning departments, developers, planners, engineers and other interested parties apply the healthy built environment principles in the Checklist whenever they plan or review new developments or redevelopments projects. We also ask you to share this list with others to increase community awareness on healthy community design.

William P. Kenoi
Mayor



PLANNING DEPARTMENT
COUNTY OF HAWAII
2015 JUN 10 10:03

Darren J. Rosario
Fire Chief
Renwick J. Victorino
Deputy Fire Chief

County of Hawai'i
HAWAII FIRE DEPARTMENT
25 Aupuni Street • Suite 2501 • Hilo, Hawai'i 96720
(808) 932-2900 • Fax (808) 932-2928

June 8, 2015

TO : DUANE KANUHA, PLANNING DIRECTOR

FROM : DARREN J. ROSARIO, FIRE CHIEF

SUBJECT : Variance – VAR- [REDACTED]
Applicant: Sydney Fuke, Planning Consultant
Owners: [REDACTED]
Request: Variance from Chapter 23, Subdivisions, Article 6, Division 2,
Improvements Required, Section 23-84, Water Supply
Tax Map Key: [REDACTED]

In regards to the above-mentioned Variance application, the following shall be in accordance:

NFPA 1, UNIFORM FIRE CODE, 2006 EDITION

Note: Hawai'i State Fire Code, National Fire Protection Association 2006 version, with County of Hawai'i amendments. County amendments are identified with a preceding "C" of the reference code.

Chapter 18 Fire Department Access and Water Supply

18.1 General. Fire department access and water supplies shall comply with this chapter.

For occupancies of an especially hazardous nature, or where special hazards exist in addition to the normal hazard of the occupancy, or where access for fire apparatus is unduly difficult, or areas where there is an inadequate fire flow, or inadequate fire hydrant spacing, and the AHJ may require additional safeguards including, but not limited to, additional fire appliance units, more than one type of appliance, or special systems suitable for the protection of the hazard involved.

EXHIBIT
B

099203



18.1.1 Plans.

18.1.1.1 Fire Apparatus Access. Plans for fire apparatus access roads shall be submitted to the fire department for review and approval prior to construction.

18.1.1.2 Fire Hydrant Systems. Plans and specifications for fire hydrant systems shall be submitted to the fire department for review and approval prior to construction.

C 18.1.1.2.1 Fire Hydrant use and Restrictions. No unauthorized person shall use or operate any Fire hydrant unless such person first secures permission or a permit from the owner or representative of the department, or company that owns or governs that water supply or system. Exception: Fire Department personnel conducting firefighting operations, hydrant testing, and/or maintenance, and the flushing and acceptance of hydrants witnessed by Fire Prevention Bureau personnel.

18.2 Fire Department Access.

18.2.1 Fire department access and fire department access roads shall be provided and maintained in accordance with Section 18.2.

18.2.2* Access to Structures or Areas.

18.2.2.1 Access Box(es). The AHJ shall have the authority to require an access box(es) to be installed in an accessible location where access to or within a structure or area is difficult because of security.

18.2.2.2 Access to Gated Subdivisions or Developments. The AHJ shall have the authority to require fire department access be provided to gated subdivisions or developments through the use of an approved device or system.

18.2.2.3 Access Maintenance. The owner or occupant of a structure or area, with required fire department access as specified in 18.2.2.1 or 18.2.2.2, shall notify the AHJ when the access is modified in a manner that could prevent fire department access.

18.2.3 Fire Department Access Roads. (*may be referred as FDAR)

18.2.3.1 Required Access.

18.2.3.1.1 Approved fire department access roads shall be provided for every facility, building, or portion of a building hereafter constructed or relocated.

18.2.3.1.2 Fire Department access roads shall consist of roadways, fire lanes, parking lots lanes, or a combination thereof.

18.2.3.1.3* When not more than two one- and two-family dwellings or private garages, carports, sheds, agricultural buildings, and detached buildings or structures 400ft² (37 m²) or less are present, the requirements of 18.2.3.1 through 18.2.3.2.1 shall be permitted to be modified by the AHJ.

18.2.3.1.4 When fire department access roads cannot be installed due to location on property, topography, waterways, nonnegotiable grades, or other similar conditions, the AHJ shall be authorized to require additional fire protection features.

18.2.3.2 Access to Building.

18.2.3.2.1 A fire department access road shall extend to within in 50 ft (15 m) of at least one exterior door that can be opened from the outside that provides access to the interior of the building. Exception: 1 and 2 family dwellings.

18.2.3.2.1.1 When buildings are protected throughout with an approved automatic sprinkler system that is installed in accordance with NFPA 13, NFPA 13D, or NFPA 13R, the distance in 18.2.3.2.1 shall be permitted to be increased to 300 feet.

18.2.3.2.2 Fire department access roads shall be provided such that any portion of the facility or any portion of an exterior wall of the first story of the building is located not more than 150 ft (46 m) from fire department access roads as measured by an approved route around the exterior of the building or facility.

18.2.3.2.2.1 When buildings are protected throughout with an approved automatic sprinkler system that is installed in accordance with NFPA 13, NFPA 13D, or NFPA 13R, the distance in 18.2.3.2.2 shall be permitted to be increased to 450 ft (137 m).

18.2.3.3 Multiple Access Roads. More than one fire department access road shall be provided when it is determined by the AHJ that access by a single road could be impaired by vehicle congestion, condition of terrain, climatic conditions, or other factors that could limit access.

18.2.3.4 Specifications.

18.2.3.4.1 Dimensions.

C 18.2.3.4.1.1 FDAR shall have an unobstructed width of not less than 20ft with an approved turn around area if the FDAR exceeds 150 feet. **Exception:** FDAR for one and two family dwellings shall have an unobstructed width of not less than 15 feet, with an area of not less than 20 feet wide within 150 feet of the structure being protected. An approved turn around area shall be provided if the FDAR exceeds 250 feet.

C 18.2.3.4.1.2 FDAR shall have an unobstructed vertical clearance of not less than 13ft 6 in.

C 18.2.3.4.1.2.1 Vertical clearances may be increased or reduced by the AHJ, provided such increase or reduction does not impair access by the fire apparatus, and approved signs are installed and maintained indicating such approved changes.

18.2.3.4.1.2.2 Vertical clearances shall be increased when vertical clearances or widths are not adequate to accommodate fire apparatus.

C 18.2.3.4.2 Surface. Fire department access roads and bridges shall be designed and maintained to support the imposed loads (25 Tons) of the fire apparatus. Such FDAR and shall be comprised of an all-weather driving surface.

18.2.3.4.3 Turning Radius.

C 18.2.3.4.3.1 Fire department access roads shall have a minimum inside turning radius of 30 feet, and a minimum outside turning radius of 60 feet.

18.2.3.4.3.2 Turns in fire department access road shall maintain the minimum road width.

18.2.3.4.4 Dead Ends. Dead-end fire department access roads in excess of 150 ft (46 m) in length shall be provided with approved provisions for the fire apparatus to turn around.

18.2.3.4.5 Bridges.

18.2.3.4.5.1 When a bridge is required to be used as part of a fire department access road, it shall be constructed and maintained in accordance with county requirements.

18.2.3.4.5.2 The bridge shall be designed for a live load sufficient to carry the imposed loads of fire apparatus.

18.2.3.4.5.3 Vehicle load limits shall be posted at both entrances to bridges where required by the AHJ.

18.2.3.4.6 Grade.

C 18.2.3.4.6.1 The maximum gradient of a Fire department access road shall not exceed 12 percent for unpaved surfaces and 15 percent for paved surfaces. In areas of the FDAR where a Fire apparatus would connect to a Fire hydrant or Fire Department Connection, the maximum gradient of such area(s) shall not exceed 10 percent.

18.2.3.4.6.2* The angle of approach and departure for any means of fire department access road shall not exceed 1 ft drop in 20 ft (0.3 m drop in 6 m) or the design limitations of the fire apparatus of the fire department, and shall be subject to approval by the AHJ.

18.2.3.4.6.3 Fire department access roads connecting to roadways shall be provided with curb cuts extending at least 2 ft (0.61 m) beyond each edge of the fire lane.

18.2.3.4.7 Traffic Calming Devices. The design and use of traffic calming devices shall be approved the AHJ.

18.2.3.5 Marking of Fire Apparatus Access Road.

18.2.3.5.1 Where required by the AHJ, approved signs or other approved notices shall be provided and maintained to identify fire department access roads or to prohibit the obstruction thereof of both.

18.2.3.5.2 A marked fire apparatus access road shall also be known as a fire lane.

18.2.4* Obstruction and Control of Fire Department Access Road.

18.2.4.1 General.

18.2.4.1.1 The required width of a fire department access road shall not be obstructed in any manner, including by the parking of vehicles.

18.2.4.1.2 Minimum required widths and clearances established under 18.2.3.4 shall be maintained at all times.

18.2.4.1.3* Facilities and structures shall be maintained in a manner that does not impair or impede accessibility for fire department operations.

18.2.4.1.4 Entrances to fire departments access roads that have been closed with gates and barriers in accordance with 18.2.4.2.1 shall not be obstructed by parked vehicles.

18.2.4.2 Closure of Accessways.

18.2.4.2.1 The AHJ shall be authorized to require the installation and maintenance of gates or other approved barricades across roads, trails, or other accessways not including public streets, alleys, or highways.

18.2.4.2.2 Where required, gates and barricades shall be secured in an approved manner.

18.2.4.2.3 Roads, trails, and other accessways that have been closed and obstructed in the manner prescribed by 18.2.4.2.1 shall not be trespassed upon or used unless authorized by the owner and the AHJ.

18.2.4.2.4 Public officers acting within their scope of duty shall be permitted to access restricted property identified in 18.2.4.2.1.

18.2.4.2.5 Locks, gates, doors, barricades, chains, enclosures, signs, tags, or seals that have been installed by the fire department or by its order or under its control shall not be removed, unlocked, destroyed, tampered with, or otherwise vandalized in any manner.

18.3 Water Supplies and Fire Hydrants

18.3.1* A water supply approved by the county, capable of supplying the required fire flow for fire protection shall be provided to all premises upon which facilities or buildings, or portions thereof, are hereafter constructed, or moved into or within the county. When any portion of the facility or building is in excess of 150 feet (45 720 mm) from a water supply on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the AHJ. For on-site fire hydrant requirements see section 18.3.3.

EXCEPTIONS:

1. When facilities or buildings, or portions thereof, are completely protected with an approved automatic fire sprinkler system the provisions of section 18.3.1 may be modified by the AHJ.
2. When water supply requirements cannot be installed due to topography or other conditions, the AHJ may require additional fire protection as specified in section 18.3.2 as amended in the code.
3. When there are not more than two dwellings, or two private garage, carports, sheds and agricultural. Occupancies, the requirements of section 18.3.1 may be modified by AHJ.

18.3.2* Where no adequate or reliable water distribution system exists, approved reservoirs, pressure tanks, elevated tanks, fire department tanker shuttles, or other approved systems capable of providing the required fire flow shall be permitted.

18.3.3* The location, number and type of fire hydrants connected to a water supply capable of delivering the required fire flow shall be provided on a fire apparatus access road on the site of the premises or both, in accordance with the appropriate county water requirements.

18.3.4 Fire Hydrants and connections to other approved water supplies shall be accessible to the fire department.

18.3.5 Private water supply systems shall be tested and maintained in accordance with NFPA 25 or county requirements as determined by the AHJ.

18.3.6 Where required by the AHJ, fire hydrants subject to vehicular damage shall be protected unless located within a public right of way.

18.3.7 The AHJ shall be notified whenever any fire hydrant is placed out of service or returned to service. Owners of private property required to have hydrants shall maintain hydrant records of approval, testing, and maintenance, in accordance with the respective county water requirements. Records shall be made available for review by the AHJ upon request.

C 18.3.8 Minimum water supply for buildings that do not meet the minimum County water standards:

Buildings up to 2000 square feet, shall have a minimum of 3,000 gallons of water available for Firefighting.

Buildings 2001- 3000 square feet, shall have a minimum of 6,000 gallons of water available for Firefighting.

Buildings, 3001- 6000 square feet, shall have a minimum of 12,000 gallons of water available for Firefighting.

Buildings, greater than 6000 square feet, shall meet the minimum County water and fire flow requirements.

Multiple story buildings shall multiply the square feet by the amount of stories when determining the minimum water supply.

Commercial buildings requiring a minimum fire flow of 2000gpm per the Department of Water standards shall double the minimum water supply reserved for firefighting.

Fire Department Connections (FDC) to alternative water supplies shall comply with 18.3.8 (1)-(6) of *this code*.

NOTE: In that water catchment systems are being used as a means of water supply for firefighting, such systems shall meet the following requirements:

- 1) In that a single water tank is used for both domestic and firefighting water, the water for domestic use shall not be capable of being drawn from the water reserved for firefighting;
- 2) Minimum pipe diameter sizes from the water supply to the Fire Department Connection (FDC) shall be as follows:
 - (a) 4" for C900 PVC pipe;
 - (b) 4" for C906 PE pipe;
 - (c) 3" for ductile Iron;
 - (d) 3' for galvanized steel.
- 3) The Fire Department Connection (FDC) shall:
 - (a) be made of galvanized steel;
 - (b) have a gated valve with 2-1/2 inch, National Standard Thread male fitting and cap;
 - (c) be located between 8 ft and 16 ft from the Fire department access. The location shall be approved by the AHJ;
 - (d) not be located less than 24 inches, and no higher than 36 inches from finish grade, as measured from the center of the FDC orifice;
 - (e) be secure and capable of withstanding drafting operations. Engineered stamped plans may be required;
 - (f) not be located more than 150 feet of the most remote part, but not less than 20 feet, of the structure being protected;
 - (g) also comply with section 13.1.3 and 18.2.3.4.6.1 of *this code*;
- 4) Commercial buildings requiring a fire flow of 2000gpm shall be provided with a second FDC. Each FDC shall be independent of each other, with each FDC being capable of flowing 500gpm by engineered design standards. The second FDC shall be located in an area approved by the AHJ with the idea of multiple Fire apparatus' conducting drafting operations at once, in mind.
- 5) Inspection and maintenance shall be in accordance to NFPA 25.
- 6) The owner or lessee of the property shall be responsible for maintaining the water level, quality, and appurtenances of the system.

Duane Kanuha
June 8, 2015
Page 9

EXCEPTIONS TO SECTION 18.3.8:


- 1) Agricultural buildings, storage sheds, and shade houses with no combustible or equipment storage.
- 2) Buildings less than 800 square feet in size that meets the minimum Fire Department Access Road requirements.
- 3) For one and two family dwellings, agricultural buildings, storage sheds, and detached garages 800 to 2000 square feet in size, and meets the minimum Fire Department Access Road requirements, the distance to the Fire Department Connection may be increased to 1000 feet.
- 4) For one and two family dwellings, agricultural buildings, and storage sheds greater than 2000 square feet, but less than 3000 square feet and meets the minimum Fire Department Access Road requirements, the distance to the Fire Department Connection may be increased to 500 feet.
- 5) For buildings with an approved automatic sprinkler system, the minimum water supply required may be modified.

If there are any questions regarding these requirements, please contact the Fire Prevention Bureau at (808) 932-2911.



DARREN J. ROSARIO
Fire Chief

RP:nac



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAII

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAII 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

February 1, 2018

TO: Mr. Michael Yee, Director
Planning Department

FROM: Keith K. Okamoto, Manager–Chief Engineer

SUBJECT: **Preliminary Plat Map and Defer Action**
Subdividers – BHD Group LLC
Tax Map Key 2-8-014:013 (SUB 17-001772)

2018 FEB 2 pm 2 29
PLANNING DEPARTMENT
COUNTY OF HAWAII

We have reviewed the subject request and have the following comments and conditions.

There is an existing waterline within Kokoke Kai Place fronting the subject parcel. The subject parcel is served by one (1) existing 5/8-inch meter (Account No 500-91098).

For your information, the water availability in the area of the subject parcels is limited to seven (7) units of water, or seven (7) 5/8-inch meters, per pre-existing lot of record. A pre-existing lot of record is considered a lot that existed prior to the implementation of the Subdivision Code in 1967. Each unit of water is equal to an average daily usage of 400 gallons and suitable for only one (1) single-family dwelling.

Please be informed that the subject parcel was created from a prior 7-lot subdivision that took place in 1993, Subdivision Application No. 6374, which created the subject parcel and six (6) additional lots. Through the 1993 subdivision, one (1) unit of water was assigned to Parcel 013.

Therefore, the Department's existing water system facilities cannot support the proposed subdivision at this time. Extensive improvements and additions, which may include, but not be limited to, source, storage, booster pumps, transmission, and distribution facilities, would be required.

The Department also requests that the plat map be revised to show the location of the existing meter with the meter number, so that we can verify this service is assigned to the subject parcel. If the existing meter is assigned to the subject parcel, the applicant must designate, in writing, which lot within the proposed subdivision will be assigned the existing meter. Should the existing meter or service lateral not front the parcel that it will serve, the existing meter or service lateral would need to be relocated to comply with the Department's Rules and Regulations.

Further, the applicant shall be informed that the existing meter shall not be shared with the other

EXHIBIT

C

... Water, Our Most Precious Resource ... Ka Wai A Kane ...

The Department of Water Supply is an Equal Opportunity provider and employer.

110551

Mr. Michael Yee, Director
Page 2
February 1, 2018

proposed lots; and the water system piping between the lots shall not be interconnected in any way.

Should there be any questions, please contact Mr. Troy Samura of our Water Resources and Planning Branch at 961-8070, extension 255.

Sincerely yours,

A handwritten signature in black ink, appearing to read 'kokoamato', written in a cursive style.

Keith K. Okamoto, P.E.
Manager-Chief Engineer

TS:dfg

copy - The Independent Hawaii Surveyors, LLC
BHD Group LLC